

Notes:

- All nail fixings pre-drilled minimum 1mm diameter smaller than nail gauge
- All products to be pre-coated & cut edges to be sealed as per Branz Bulletin 411
- All materials and fixtures are to comply with E2/AS1 clause 2.2
- Provide PVC tape bond break between H3.2 battens and any flashing
- Vertical Shiplap profiles to be fixed with a minimum 2mm gap at the overlap between boards
- Rigid & Flexible underlay as per table 23 and clauses 9.1.5 to 9.1.7
- Timber to NZBC B2 durability B2.3.1 (b), Western Red Cedar, Larch

6mm Fibre cement Rigid Wall Underlay
As per table 23 and clauses 9.1.5 to 9.1.7 and 9.1.7.2 E2/AS1

Framing

CCA treated H3.2 45x20mm
BBS "V" timber cavity batten

75mm annular grooved
rose head, silicone bronze
or stainless steel nail

9x9mm compressible
foam strip

Powder coated external corner
extrusion hem edge, folds
compatibility to comply with
NZBC E2/AS1

50 min
from edge

80mm PBS Butyl tape lapped
evenly to corner over a 100mm
strip PBS Butyl primer

BBS Vertical Shiplap Weatherboard

CCA treated H3.2 45x20mm
BBS "H" timber cavity batten.
Horizontal @ 480mm max centres

copyright BBS Timbers LTD ©

External corner detail

TITLE:

	NAME	SIGNATURE	DATE	Rev
DRAWN				
CHK'D				
APP'VD				



27 Kioreroa road
PO Box 1407
Whangarei
09 438 9358

DWG NO.

VC-RB-06

A4

SCALE:1:5 DNS SHEET 1 OF 1